

## **EXECUTIVE SUMMARY 2007 WATER SYSTEM PLAN**

Water District 19's 2007 Water System Plan represents a compilation of planning and engineering studies completed by PACE Engineers, Inc., District staff, and the Board of Commissioners. The purpose of the Plan is to determine the adequacy of Water District 19's existing water system to meet the existing and projected needs of the customers of the District. The Plan also provides a long-range planning document that addresses the regulations and concerns associated with operating a public water system within the community of Vashon Island. The Plan supersedes and updates the District's current water system plan, the year 2000 King County Water District 19 Water System Plan prepared by

Gray & Osborne, Inc. and incorporates a variety of information and findings from that document and other planning and engineering studies prepared for the District by other consulting firms.

### **WATER DISTRICT 19 Vashon Island, WA**



The 2007 Water System Plan has been prepared in accordance with the rules and regulations governing the operation of public water and sewer systems as administered by the State of Washington Departments of Health and Ecology (DOH and DOE respectively), King County, and the codes and policies of all other agencies having jurisdiction. In accordance with regulatory requirements and District needs, the Plan includes a summary of existing District policies, a complete analysis of demographic trends and projections for the service area, documentation of past water use trends and future demand projections, a complete inventory of the water system, establishment of minimum design criteria in accordance with the most current DOH standards, evaluation of the system under current criteria, presentation of recommended improvements in the form of a prioritized Capital Improvement Program, and a summary of financial alternatives for implementing the recommendations presented. In addition, State regulations and especially the recently enacted Municipal Water Law (HB 1338) require documentation of various operational aspects of the District, including the current water quality monitoring schedules and programs, emergency response activities, water rights self assessment and documentation related to water use efficiency programs.

### **WATER DISTRICT 19 HISTORY AND LOCATION**


Water District 19 is the only Group A Public water System on Vashon Island and operates under the authority and requirements of RCW Title 57 – Sewer and Water Districts. The District was established in 1925 by special election and at the time, encompassed only one square mile surrounding the unincorporated town of Vashon. Through annexations and the Coordinated Water System Plan service area agreement process in the late 1980's, the District has grown to include a retail service area and corporate boundary of just over six square miles. All residents

within the corporate area vote for the Board of three Commissioners, elected at-large from the community.

The original distribution system consisted of about 2 miles of dipped and wrapped wrought iron pipe. Storage consisted of a 20,000 gallon elevated wood tank.

The original source of supply consisted of two small dams just to the north of the mouth of Beall Creek. In 1969, Island Mutual Water Company was annexed into the District and brought an additional source online.

Improvements to the system over the years have included development of additional sources of supply, storage reservoirs and extension of transmission and distribution system lines to serve the current service area. In addition, several sources of supply and associated treatment and pumping facilities have been abandoned and/or replaced. Of particular note is that water supply sources have required replacement as water yield decreased from the original facilities.



As of January 2007, the District serves 1,421 connections, up from 1,293 as of the 2000 Water System Plan. Service is accomplished through three groundwater wells, two surface water sources, a water treatment plant, 1.725 million gallons of water storage capacity and many miles of transmission and distribution mains ranging in size from 3/4-inch to 16-inches in diameter. The 6.2 square mile service area generally extends from SW 160<sup>th</sup> Street on the north to a small area on the northern portion of Maury Island on the south. On the east the District is bounded by Puget Sound and on the west, the service area extends to approximately 115<sup>th</sup> Avenue SW and 103<sup>rd</sup> Avenue SW. In the southernmost portion of the District the service area extends onto Maury Island, to SW 240<sup>th</sup> Street and Dockton Road. It is important to note that not all properties within the service area receive water from Water District 19 and instead rely on the use of private wells.

**POPULATION AND EMPLOYMENT**

As part of the planning process, the current (2006) and projected population and employment within Water District 19's retail water service areas were estimated. In order to estimate the population and employment figures, District planning documents and billing records were reviewed as well as current projections from the Puget Sound Regional Council (PSRC) and King County. The population data used in developing the projections is based on 2000 US Census and 2005 PSRC block group data.

Currently an estimated 3,400 people reside within the water service area and approximately 1,300 people are employed within the same area. While most of the businesses and employees within the service area are served by the District (excluding some home occupations), the number of residents actually served requires consideration of private wells within the service


area. By multiplying the number of active residential accounts by the average household size, it is estimated that approximately 2,975 people of the total 3,400 residents are actually served by Water District 19.

The total population and employees within the service area is expected to increase to approximately 3,800 and 1,480 (respectively) by the twenty-year planning horizon of 2026

**WATER DEMANDS**

Identification of historical and projected water system demands is a critical element of the planning process. The demand projections are used in the evaluation of the water system’s ability to meet the needs of current and future populations of the District’s water service area and provide the basis for water system modeling and analysis.

Water District 19 produces all of the water sold to customers through its existing supply facilities and treatment plant. The District’s non-revenue water, which is water lost through leaks in the system, operational water uses (flushing mains, etc.), water used for construction purposes and unauthorized water withdrawals from hydrants, is estimated at 8%. This number, while well within the State guideline of 10%, is constantly monitored and reviewed by the District as a means of protecting the finite resource and maintaining efficiency of the system.



The District supplies water to approximately 1,202 single-family residential, 20 multi-family residential, 159 commercial and 31 public connections. Evaluation of water use by customer class is accomplished by expressing multi-family, commercial and school customers in Equivalent Residential Units or ERUs and at the end of 2006, the District’s 1,421 connections was equal to an estimated 1,621 ERUs. The average day demand from 2002 to 2006 was 197 gallons per day per ERU, excluding unaccounted for water. Adding the average unaccounted for water amount to this results in an average demand of 213 gallons per day per ERU. Based on historical data, the maximum day demand peaking factor of 2.88 is applied to average day demand numbers to arrive at the peak day usage that is required for evaluation of system facilities and the ability to meet water demands under all circumstances. The relatively high peaking factor (compared to regional norms) is a result of rural summer water usage, and is the

limiting factor on system expansion. It is the subject of considerable discussion in the plan and is the basis for the District’s Water Use Efficiency (or Conservation Program).

Future demands were projected with and without conservation, based on Department of Health requirements and are summarized in the following graph. Although an aggressive Water Use Efficiency program is proposed to assist in conservation of resources and reduction in peak day demands, the water system has been evaluated without consideration of conservation. As the conservation goals are met and documented by water use figures, consideration of additional evaluation under reduced water use per connection may be warranted.

**WATER SYSTEM ANALYSIS**

Analysis of the existing water system was completed to determine the requirements for the maintenance of high quality water supply and service at a reasonable cost to the ratepayers of the system.



**SOURCE OF SUPPLY**

The source of supply analysis indicates that water rights are sufficient to meet the current and anticipated needs of the District through the six and twenty-year planning periods. Water supply is limited, however, by the inability of the existing sources of supply to keep up with historic peak water system demands. While the existing sources of supply are adequate to meet projected average day demands, difficulties in meeting peak day demand with the existing facilities is the limiting system factor prohibiting the addition of new connections to the system. Table 6-1 (shown below and detailed in Section 6 of this Plan) outlines the discrepancy between existing water rights and yields.

TABLE 6-1 INSTANTANEOUS PRODUCTION ANALYSIS			
Source	Instantaneous Water Right (gpm)	Winter Production Capacity (gpm)	Summer Production Capacity (gpm)
Wells 1,2 & 4	250	150	150
Beall Well	180	(1)	(1)
Beall Creek	404	404	300 (2)
Ellis Creek	224	224	150 (2)

(1) Depends on the District’s ability to perfect the water right.  
(2) Limited by summer creek flows.

Several alternatives have been identified and pursued by the District over recent years, the most promising of which is development of the Beall Well to produce approximately 80 gallons per minute of peak day supply and augment existing supply. While this small

yield is not expected to alleviate the restricted water supply issue, it will contribute to the ability to meet summer peak demands. Final development of the well is proposed for 2008. Water Use Efficiency measures may also contribute to reducing summertime peak demands but are dependent on customer acceptance and willingness to recognize and conserve water as a finite resource. The possible transfer of existing groundwater rights to the Morgan Hill well and recommended addition of booster pump at the existing storage reservoirs may also increase peak summer supply. Longer term water supply alternatives that have been identified and recommended for further analysis include development of additional wells, or construction of a new source through a desalinization plant, impoundment of rainwater at an open pond or reservoir, or piping from an off-island source. It is noted that a pipeline from off-Island sources is specifically restricted in current King county planning policies, and would require an enormous investment for a District of this size.

### ***WATER RESOURCE PROTECTION***

Documentation of the District's water resource protection program has been accomplished as part of the planning process and no additional recommendations to the existing program have been identified.

### ***STORAGE ANALYSIS***

The storage analysis of the system indicated that sufficient storage is in place to meet current and anticipated storage requirements. A large quantity of water in the existing storage configuration is unavailable for use due to hydraulic grade-lines. In other words, the elevation of the storage water is below what is required to deliver water at the minimum of 30 psi. This quantity of water is common in water storage reservoirs and is referred to as "dead storage". It is typically used to offset the expense of constructing elevated water reservoirs. Through pumping improvements, it is recommended that the District convert the dead storage to usable storage and in doing so, make the water available for emergency conditions and to help meet summer peak day conditions. Additional analysis of this alternative through development of an engineering report and pre-design study is recommended to obtain a DOH position on using dead storage as a means of supplementing water supply.

### ***TRANSMISSION AND DISTRIBUTION***

Analysis of the transmission and distribution system was accomplished with the use of a hydraulic model. The modeling results indicate that there are several areas in the District that will require system upgrades to meet the minimum fire flow requirement. In addition, there is a significant amount of pipe within the system that is either undersized for current standards, is beyond its useful life and/or is of material that is cannot be expected to operate without leaks or future breaks. Of particular concern is Asbestos Cement (AC pipe) that was installed in the 1950's and 1960's. This pipe material has not lived up to

the expected life of pipe and tends to fail catastrophically rather than exhibit small leaks and cracks. Undersized and AC mains should be prioritized in the District's ongoing renewal and replacement strategy.

### **CAPITAL FACILITIES PLAN**

Section 9 of the Plan presents a capital facilities plan for the proposed water system improvements. The cost estimates are based on 2007 prices and reflect total project costs, including construction costs plus contingency and overhead costs such as District administration, engineering, legal fees, taxes, etc. A summary of the projects prioritized for the six-year planning horizon is presented below.

- 1. Treatment Plant Chlorination project** – *Estimated cost -\$10,000.* This project will improve chlorination control by adding chlorine monitoring at the end of surface water treatment process. Implementation is planned for late 2007 – 2008.
- 2. Beall Well Implementation project** – *Estimated cost \$100,000 - \$200,000.* The Beall test well has been completed. This project covers engineering services and infrastructure implementation to add this source to the distribution system and integrate the well with the existing SCADA control system. Implementation is planned for 2008. In addition, ongoing analysis of source alternatives is proposed.
- 3. Tank Farm Booster Station** – *Estimated cost \$100,000 - \$500,000.* The fire flow at areas near the two main tanks can be increased by boosting the pressure at the tanks. This will also enable more of the storage in the million gallon tank to be used to meet peak day demand. Implementation is planned for 2008.
- 4. On-going Water Main Replacement projects** – *Estimated average cost \$100,000 per year.*

### **FINANCING AND IMPLEMENTATION**

Financing of water system improvements is a key element of any water system planning effort. It is recommended that the District complete a full rate study and connection charge assessment following adoption of this Plan. The rate study should focus on implementation of prioritized projects, maintenance of a sufficient emergency reserve, equity of rates between customer classes and the stated goal of achieving water conservation during the peak season months.

In addition to rates, the District should review all available sources of external grants and financing. The size and rural nature of the community lends itself well to a federally assisted grant and loan program administered by the federal government through the Rural Development agency. Although the portion of grant funding available the RD program is income dependent, that requirement is mitigated through consideration of existing rates in relation to income levels. Other programs that may prove viable for financing are the grant and low interest loan programs associated with the State Revolving Fund and Public Works Trust Fund.

**WATER DISTRICT 19  
2007 COMPREHENSIVE PLAN  
TABLE OF CONTENTS**

PROJECT CERTIFICATION ..... I  
EXECUTIVE SUMMARY ..... II  
TABLE OF CONTENTS ..... VIII  
LIST OF TABLES ..... XIV  
LIST OF FIGURES ..... XV  
GLOSSARY ..... XVI

**SECTION 1 – INTRODUCTION**

1.1 INTRODUCTION ..... 1-1  
1.2 SYSTEM OWNERSHIP AND MANAGEMENT ..... 1-1  
1.3 WATER SYSTEM POLICIES ..... 1-2  
1.4 SYSTEM BACKGROUND ..... 1-8  
    1.4.1 HISTORY OF THE DISTRICT ..... 1-8  
1.5 RULES AND REGULATIONS ..... 1-9  
    1.5.1 FEDERAL REGULATIONS ..... 1-9  
        1.5.1.1 SAFE DRINKING WATER ACT ..... 1-9  
        1.5.1.2 CLEAN WATER ACT ..... 1-9  
        1.5.1.3 ENDANGERED SPECIES ACT ..... 1-10  
    1.5.2 STATE OF WASHINGTON REQUIREMENTS ..... 1-10  
        1.5.2.1 WASHINGTON ADMINISTRATIVE CODE & REVISED CODE OF WASHINGTON ..... 1-10  
        1.5.2.2 GROWTH MANAGEMENT ACT ..... 1-10  
        1.5.2.3 MUNICIPAL WATER LAW ..... 1-11  
        1.5.2.4 DEPARTMENT OF HEALTH ..... 1-11  
        1.5.2.5 PUBLIC WATER SYSTEM COORDINATION ACT ..... 1-11  
    1.5.3 KING COUNTY REQUIREMENTS ..... 1-12  
1.6 RELATED PLANNING DOCUMENTS ..... 1-12

**SECTION 2 – BASIC PLANNING DATA**

2.1 OVERVIEW ..... 2-1  
2.2 SERVICE AREA CHARACTERISTICS ..... 2-1  
    2.2.2 PHYSICAL CHARACTERISTICS ..... 2-1  
        2.2.2.1 TOPOGRAPHY ..... 2-1  
        2.2.2.2 WATER SURFACE FEATURES ..... 2-2  
        2.2.2.3 CLIMATE AND RAINFALL ..... 2-2  
        2.2.2.4 GEOLOGY AND SOILS ..... 2-2  
        2.2.2.5 SENSITIVE AREAS ..... 2-3  
        2.2.2.6 ECONOMY ..... 2-4  
        2.2.2.7 TRANSPORTATION ..... 2-4  
2.3 FUTURE SERVICE AREA ..... 2-4  
2.4 ADJACENT PURVEYORS ..... 2-9  
    2.4.1 HEIGHTS WATER ..... 2-9  
    2.4.2 WESTSIDE WATER ASSOCIATION ..... 2-9

2.4.3	BURTON WATER COMPANY .....	2-9
2.4.4	MAURY MUTUAL WATER COMPANY.....	2-10
2.4.5	DOCKTON WATER ASSOCIATION.....	2-10
2.5	LAND USE AND ZONING .....	2-10
2.5.1	ZONING AND FUTURE LAND USE .....	2-10
2.6	EXISTING MORATORIUM .....	2-13
2.7	POPULATION AND EMPLOYMENT .....	2-14
2.8	NUMBER OF CONNECTIONS AND AREA SERVED .....	2-15
2.9	WATER DEMAND.....	2-16
2.9.1	EQUIVALENT RESIDENTIAL UNIT (ERU).....	2-16
2.9.2	PEAKING FACTOR.....	2-17
2.9.3	HISTORICAL WATER PRODUCTION AND SALES .....	2-17
2.10	PROJECTED WATER DEMANDS .....	2-21

**SECTION 3 – EXISTING SYSTEM**

3.1	GENERAL.....	3-1
3.2.	WATER RIGHTS.....	3-1
3.2.2	SOURCE OF SUPPLY.....	3-1
3.2.2.1	GROUNDWATER.....	3-1
3.2.2.2	SURFACE WATER .....	3-2
3.2.3	TREATMENT .....	3-5
3.2.4	STORAGE .....	3-6
3.2.5	BOOSTER STATIONS.....	3-6
3.2.6	TRANSMISSION AND DISTRIBUTION SYSTEM .....	3-7
3.2.7	INTERTIES .....	3-8
3.2.8	PRESSURE REDUCING VALVES (PRVs) .....	3-8

**SECTION 4 – CONSERVATION AND REUSE**

4.1	INTRODUCTION .....	4-1
4.2.	WATER CONSERVATION PLAN .....	4-2
4.2.1	WATER USE DATA COLLECTION.....	4-3
4.2.2	DEMAND FORECASTING.....	4-4
4.2.3	CONSERVATION MANAGEMENT STRATEGIES .....	4-4
4.2.4	CONSERVATION PLAN ELEMENTS .....	4-7
4.2.5	CONSERVATION PLAN ACTIVITIES .....	4-7
4.2.6	CONSERVATION PROGRAM EVALUATION .....	4-11
4.2.7	WATER REUSE.....	4-11
4.2.8	WATER USE EFFICIENCY .....	4-11

**SECTION 5 – MINIMUM DESIGN CRITERIA**

5.1.	INTRODUCTION .....	5-1
5.1.1	STATE AGENCY REGULATIONS .....	5-1
5.2	REFERENCE DATUM.....	5-1
5.3	DESIGN PLANNING PERIOD.....	5-1
5.4	PLANNING CONSIDERATIONS .....	5-2
5.5	RELIABILITY CONSIDERATIONS .....	5-2

5.6 WATER SUPPLY ..... 5-2

5.7 WATER PRESSURE ..... 5-2

5.8 PIPE SIZING AND MATERIALS ..... 5-2

5.9 VALVES ..... 5-3

5.10 FIRE HYDRANTS ..... 5-4

5.11 CROSS-CONNECTIONS CONTROL ..... 5-4

5.12 STORAGE ..... 5-4

    5.12.1 EFFECTIVE STORAGE ..... 5-4

    5.12.2 OPERATIONAL STORAGE ..... 5-5

    5.12.3 EQUALIZING STORAGE ..... 5-5

    5.12.4 STANDBY STORAGE ..... 5-5

    5.12.5 FIRE SUPPRESSION STORAGE ..... 5-5

    5.12.6 DEAD STORAGE ..... 5-6

5.13 PUMP STATIONS ..... 5-6

5.14 GENERAL FACILITY PLACEMENT ..... 5-6

5.15 STANDARD PLANS AND SPECIFICATIONS ..... 5-6

5.16 WATER QUALITY STANDARDS ..... 5-7

    5.16.1 EXISTING DRINKING WATER STANDARDS ..... 5-7

    5.16.2 ANTICIPATED FUTURE DRINKING WATER REGULATIONS ..... 5-8

    5.16.3 WATER QUALITY MONITORING SCHEDULE ..... 5-8

**SECTION 6 – SYSTEM ANALYSIS**

6.1 OVERVIEW ..... 6-1

6.2 SOURCE REQUIREMENTS AND ANALYSIS ..... 6-1

    6.2.1 SOURCE PRODUCTION CAPACITY ANALYSIS ..... 6-4

    6.2.2 STREAM FLOW MONITORING SUMMARY ..... 6-5

    6.2.3 SOURCE PUMP STATIONS ..... 6-5

    6.2.4 INTERTIES ..... 6-6

    6.2.5 SOURCE RECOMMENDATIONS ..... 6-6

6.3 STORAGE REQUIREMENTS AND ANALYSIS ..... 6-7

    6.3.1 OPERATIONAL STORAGE ..... 6-7

    6.3.2 DEAD STORAGE ..... 6-8

    6.3.3 EQUALIZING STORAGE ..... 6-8

    6.3.4 STANDBY STORAGE ..... 6-9

    6.3.5 FIRE SUPPRESSION STORAGE ..... 6-9

    6.3.6 STORAGE IMPROVEMENTS ..... 6-12

6.4 PUMPING FACILITIES ..... 6-13

    6.4.1 WATER TREATMENT PLANT PUMP STATION ..... 6-13

    6.4.2 TANK FARM BOOSTER PUMP STATION ..... 6-13

    6.4.3 PUMPING ANALYSIS ..... 6-13

    6.4.4 PUMPING IMPROVEMENTS ..... 6-13

6-5 DISTRIBUTION SYSTEM ..... 6-14

    6.5.1 305 PRESSURE ZONE ..... 6-14

    6.5.2 494 PRESSURE ZONE ..... 6-14

6.6 HYDRAULIC MODELING SOFTWARE ..... 6-14

    6.6.1 HYDRAULIC MODEL CALIBRATION ..... 6-15

    6.6.2 HYDRAULIC MODELING ANALYSIS ..... 6-16

6.7	DISTRIBUTION SYSTEM ANALYSIS .....	6-17
6.7.1	2006 FIRE FLOW ANALYSIS (MDD+FF AT 20 PSI OR GREATER) .....	6-17
6.7.2	2030 FIRE FLOW ANALYSIS (MDD+FF AT 20 PSI OR GREATER) .....	6-18
6.7.3	FIRE FLOW IMPROVEMENTS .....	6-18
6.7.4	2006 PHD ANALYSIS .....	6-19
6.7.5	2030 PHD ANALYSIS .....	6-19
6.7.6	PHD IMPROVEMENTS .....	6-19
6.8	NON-MODELED ANALYSIS .....	6-19
6.8.1	PRESSURE ZONE IMPROVEMENTS .....	6-19
6.8.2	WATER MAIN IMPROVEMENTS .....	6-20

**SECTION 7 – WATER RESOURCE PROTECTION**

7.1	OVERVIEW .....	7-1
7.2	WELLHEAD PROTECTION PROGRAM OVERVIEW .....	7-1
7.3	SUSCEPTIBILITY ASSESSMENT .....	7-2
7.4	WELLHEAD PROTECTION AREA DELINEATION .....	7-2
7.5	METHOD OF DELINEATION .....	7-2
7.5.1	CALCULATED FIXED RADIUS METHOD .....	7-2
7.5.2	ANALYTICAL MODELS .....	7-3
7.6	ANALYSIS .....	7-3
7.7	CONTAMINANT SOURCE INVENTORY .....	7-4
7.7.1	POTENTIAL CONTAMINANT SOURCES .....	7-4
7.7.2	LANDFILLS .....	7-9
7.7.3	COMMERCIAL AND INDUSTRIAL ACTIVITY .....	7-10
7.7.4	UNDERGROUND STORAGE TANKS .....	7-11
7.7.5	SEPTIC SYSTEM .....	7-12
7.7.6	IMPROPERLY SEALED OR SECURED WELLS .....	7-12
7.7.7	ACCIDENTAL SPILLS .....	7-12
7.7.8	CONFIRMED OR SUSPECTED CONTAMINATION SITES .....	7-12
7.8	INVENTORY OF DATA SOURCES .....	7-13
7.9	SPILL/INCIDENT RESPONSE PROGRAM .....	7-14
7.10	CONTINGENCY PLANNING .....	7-15
7.11	RECOMMENDATIONS .....	7-15
7.12	WATERSHED PROTECTION PLAN OVERVIEW .....	7-16
7.12.1	REGULATORY REQUIREMENTS/PROGRAM OVERVIEW .....	7-16
7.12.3	WATERSHED DESCRIPTION/CHARACTERISTICS .....	7-16
7.12.4	WATERSHED MANAGEMENT AND CONTROL MEASURES .....	7-17
7.12.5	MONITORING AND SYSTEM OPERATIONS .....	7-18

**SECTION 8 — OPERATIONS & MAINTENANCE**

8.1	OVERVIEW .....	8-1
8.2	GENERAL DISTRICT INFORMATION .....	8-1
8.3	DISTRICT ORGANIZATION AND MANAGEMENT .....	8-1
8.4	PERSONNEL CERTIFICATION .....	8-2
8.5	NORMAL OPERATING CONDITIONS .....	8-3
8.5.1	RESERVOIRS .....	8-3
8.5.2	TELEMETRY .....	8-4

8.5.3	SOURCES OF SUPPLY .....	8-4
8.5.4	WATER TREATMENT PLANT .....	8-5
8.6	PREVENTATIVE MAINTENANCE.....	8-6
8.6.1	RESERVOIRS.....	8-6
8.6.2	DISTRIBUTION SYSTEM, VALVE AND HYDRANT MAINTENANCE .....	8-7
8.6.3	DEAD-END WATER LINES .....	8-7
8.6.4	WATER TREATMENT PLANT .....	8-7
8.6.5	WELLS.....	8-9
8.6.6	METERS.....	8-9
8.6.7	INVENTORY OF MATERIALS .....	8-10
8.6.8	RECOMMENDED PREVENTIVE MAINTENANCE SCHEDULE .....	8-10
8.7	EMERGENCY RESPONSE PLAN .....	8-10
8.8	EMERGENCY RESPONSE PROCEDURES .....	8-13
8.8.1	POWER FAILURE .....	8-13
8.8.2	SEVERE EARTHQUAKE.....	8-13
8.8.3	SEVERE SNOWSTORM/FIRE .....	8-14
8.8.4	HIGH WATER AND FLOODING CIVIL DISTURBANCE .....	8-15
8.8.5	CONTAMINATION OF WATER SUPPLY .....	8-16
8.8.6	BACTERIOLOGICAL PRESENCE DETECTION PROCEDURE .....	8-17
	8.8.6.1 BACTERIOLOGICAL PRESENCE DETECTION PROCEDURE.....	8-18
	8.8.6.2 VOC/SOC AND INORGANIC CHARACTERISTICS DETECTION PROCEDURES .....	8-18
8.9	CROSS CONNECTION CONTROL.....	8-22
8.9.1	PRIORITY SERVICE .....	8-22
8.9.2	NEW AND EXISTING CROSS CONNECTION CONTROL DEVICES .....	8-22
8.9.3	CROSS CONNECTION CONTROL RECORD KEEPING .....	8-23
8.10	WATER QUALITY MONITORING .....	8-23

**SECTION 9 – CAPITAL IMPROVEMENT PLAN**

9.1	OVERVIEW .....	9-1
9.2	POTENTIAL CAPITAL IMPROVEMENT PROJECTS .....	9-1
9.3	PRIORITY CAPITAL PROJECTS .....	9-6

**SECTION 10 – FINANCING AND IMPLEMENTATION**

10.1	GENERAL .....	10-1
10.2	FINANCIAL CONSIDERATIONS .....	10-1
10.3	WATER SYSTEM BUDGET .....	10-1
10.4	FUNDING SOURCES .....	10-2
	10.4.1 RATES.....	10-3
	10.4.2 CONNECTION CHARGES.....	10-4
	10.4.3 UTILITY DISTRICT LOCAL IMPROVEMENT DISTRICT (ULID) FINANCING .....	10-4
	10.4.4 DEVELOPER FINANCING.....	10-5
	10.5 COMBINATION FINANCING BY DEVELOPERS AND THE DISTRICT .....	10-5
	10.4.6 BOND FINANCING.....	10-5
	10.4.7 GRANT FINANCING.....	10-5
	10.4.8 PUBLIC WORKS TRUST FUND (PWTF) LOANS .....	10-6
	10.4.9 STATE REVOLVING FUND (SRF).....	10-6
	10.4.10 RURAL DEVELOPMENT DIRECT LOANS AND GRANTS.....	10-6

10.5 FINANCING CAPITAL IMPROVEMENTS ..... 10-6  
 10.5.1 GENERAL FACILITIES ..... 10-6  
 10.5.2 LOCAL FACILITIES ..... 10-7  
 10.5.3 PRIVATE FACILITIES ..... 10-8  
 10.6 FINANCING STRATEGY ..... 10-8  
 10.7 ENVIRONMENTAL REVIEW ..... 10-8

**APPENDICES**

- SEPA CHECKLIST
- INTERLOCAL AGREEMENTS
- MUNICIPAL WATER LAW DOCUMENTATION
- WATER RIGHTS DOCUMENTATION
- WATER QUALITY
- SATELLITE MANAGEMENT
- PLAN DISTRIBUTION, COMMENTS, AND APPROVAL
- WATER SYSTEM PLAN MAP

**LIST OF TABLES**

2-1 SERVICE AREA ZONING ..... 2-3

2-2 SERVICE AREA POPULATION & EMPLOYMENT ..... 2-5

2-3 HISTORICAL ANNUAL WATER PRODUCTION AND SALES ..... 2-8

2-4 HISTORICAL AVERAGE WATER USE ..... 2-8

2-5 PROJECTED WATER DEMANDS ..... 2-22

3-1 WATER RIGHTS ..... 3-4

3-2 STORAGE FACILITIES ..... 3-6

3-3 PUMP STATIONS ..... 3-7

4-1 WATER USE DATA COLLECTION ..... 4-3

4-2 DOH RECOMMENDED WATER CONSERVATION ELEMENTS FOR  
 SYSTEMS WITH 1,000 TO 25,000 SERVICES ..... 4-6

4-3 SUMMER CONSERVATION RATES ..... 4-11

5-1 WATER QUALITY – MAXIMUM CONTAMINANT LEVELS ..... 5-9

6-1 INSTANTANEOUS PRODUCTION ANALYSIS ..... 6-3

6-2 ANNUAL PRODUCTION ANALYSIS ..... 6-3

6-3 POPULATION AND WATER DEMAND PROJECTIONS ..... 6-3

6-4 SOURCE ANALYSIS ..... 6-4

6-5 STORAGE ANALYSIS ..... 6-11

7-1 WELLHEAD PROTECTION ZONES OF CONTAMINATION ..... 7-4

7-2 POTENTIAL CONTAMINANT SOURCES ..... 7-9

7-3 CHEMICALS ASSOCIATED WITH COMMERCIAL AND INDUSTRIAL ACTIVITIES ..... 7-10

8-1 ORGANIZATION CHART ..... 8-3

8-2 WATER TREATMENT MAINTENANCE SCHEDULE ..... 8-8

8-3 PREVENTIVE MAINTENANCE SCHEDULE ..... 8-10

8-4 EMERGENCY MANAGEMENT TEAM ..... 8-11

8-5 SEVERE EARTHQUAKE EMERGENCY RESPONSE ..... 8-14

8-6 FIRE EMERGENCY RESPONSE ACTIONS ..... 8-15

8-7 CIVIL DISTURBANCE EMERGENCY RESPONSE ACTIONS ..... 8-16

8-8 CONTAMINATION EMERGENCY RESPONSE ACTIONS ..... 8-17

8-9 WATER QUALITY MONITORING ..... 8-23

9-1 POTENTIAL CAPITAL IMPROVEMENT PROJECTS ..... 9-1

9-2 CAPITAL IMPROVEMENTS PLAN ..... 9-2

10-1 WATER UTILITY ANTICIPATED SIX-YEAR BUDGET ..... 10-2

10-2 EXISTING WATER RATES ..... 10-3

**LIST OF FIGURES**

1-1 VICINITY MAP..... 1-2

2-1 BOUNDARY MAP ..... 2-5

2-2 SENSITIVE AREAS MAP ..... 2-6

2-3 ZONING MAP..... 2-9

2-4 ANNUAL WATER USE SUMMARY ..... 2-16

7-1 WELLHEAD PROTECTION AREAS..... 7-5

7-2 POTENTIAL CONTAMINANT SOURCES ..... 7-7

8-1 ORGANIZATION CHART ..... 8-3

8-2 BACTERIAL PRESENCE DETECTION PROCEDURE..... 8-19

8-3 ORGANIC CHEMICAL DETECTION PROCEDURE ..... 8-20

8-4 INORGANIC CHEMICAL/PHYSICAL CHARACTERISTIC DETECTION PROCEDURE ..... 8-21

WATER SYSTEM PLAN MAP..... APPENDICES

**GLOSSARY**

**ACRONYMS**

AC	Asbestos-Cement
ADD	Average Daily Demand
APWA	American Public Works Association
AWWA	American Water Works Association
ccf	One hundred cubic feet
cfs	Cubic Feet per second
CFP	Capital Facilities Plan
CI	Cast Iron
CRWSD	Cedar River Water and Sewer District
CT	Census Tract
CWD	Covington Water District
CWSP	Coordinated Water System Plan
CWSSA	Critical Water Supply Area
DI	Ductile Iron
DOE	Washington State Department of Ecology
DOH	Washington State Department of Health
DOT/APWA	Standard Specifications for Road, Bridge, and Municipal Construction, Washington State Department of Transportation and the American Public Works Association, 2006 Edition
EPA	United States Environmental Protection Agency
ERU	Equivalent Residential Unit
ES	Equalizing Storage
FAZ	Forecast Analysis Zone
FF	Fire Flow
FSS	Fire Suppression Storage
gpcd	Gallons per capita per day
gpd	Gallons per day
gpm	Gallons per minute
GFC	General Facility Charge
GMA	Growth Management Act
HGL	Hydraulic Grade Line
LFC	Local Facility Charge
MCL	Maximum Contaminant Level
MDD	Maximum Daily Demand
MG	Million Gallons
MGD	Million gallons per day
mg/l	Milligrams per liter
OFM	Office of Financial Management
PHD	Peak Hour Demand
PSRC	Puget Sound Regional Council
PRV	Pressure Reducing Valve
psi	Pounds per square inch

PVC	Polyvinyl Chloride
RCW	Revised Code of Washington
SDWA	Safe Drinking Water Act
SEPA	State Environmental Policy Act
UBC	Uniform Building Code
UPC	Uniform Plumbing Code
ULID	Utility Local Improvement District
USGS	United State Geological Survey
WAC	Washington Administrative Code
WFI	Water Facility Inventory and Report Form (DOH form)
WSDOT	Washington State Department of Transportation
WSRB	Washington Surveying and Rating Bureau
WUCC	Water Utility Coordinating Committee
WUTC	Washington Utilities and Transportation Commission

**TERMS**

**Annual Demand** - Total water system demand for one calendar year, expressed in millions of gallons (MG), including all uses and unaccounted for water.

**Average Daily Demand (ADD)** - The annual demand divided by the number of days per year, expressed in million gallons per day (MGD).

**Cross Connection** - A physical arrangement connecting a public water system, directly or indirectly, with anything other than another potable water system, and capable of contaminating the public water system.

**Dead Storage** - The volume of stored water not available to all customers at the minimum design pressure in accordance with WAC 246-290-230 (5) and (6).

**Equalizing Storage** - The volume of water required to meet hourly variations in demand in excess of the available rate of supply.

**Equivalent Residential Units (ERU)** - The amount of water consumed by a typical full-time single family residence. Used for converting users other than single family residences into an equivalent number for the purpose of demand forecasting, system analysis and facility sizing.

**Fire Flow** - The rate of water flow, in gpm, required to fight fires under WAC 246-293-640 or adopted city or county standards.

**Fire Suppression Storage** - The volume of water required to accommodate fire demand.

**Franchise Area** - A designated area within which the utility system is permitted, by franchise, to own, operate and maintain facilities within public rights-of-way.

**Legal Boundary** - The corporate boundary established for the District. Extension of service beyond the District's legal boundary requires annexation to the District or specific agreement for the provision of such service. Also referred to as corporate area.

**Maximum Contaminant Level (MCL)** - The maximum permissible level of a contaminant in water the purveyor delivers to any public water system user.

**Maximum Daily Demand (MDD)** - The highest water demand anticipated for any given day, expressed in MGD.

**Operational Storage** - The volume of the reservoir devoted to supplying the water system while, under normal operating conditions, the source(s) are in "off" status.

**Peak Hour Demand (PHD)** - The maximum rate of water use, excluding fire flow, which has occurred, or is expected to occur, over a one hour period of time. Typically expressed in gallons per minute.

**Potable** - Water suitable for drinking by the public.

**Pressure Zone** - A water supply or distribution subsystem operating at a uniform hydraulic gradient.

**Service Area** - The recognized area within which Cedar River Water and Sewer District intends to provide water service.

**Standby Storage** - The volume of water required to augment the available supply of water during a period of partially or fully restricted flow from the supply source, due to such things as pipeline or pump failure or power outages.

**Usable Storage** - That portion of the total available storage, which is available on a continuous basis, either by gravity flow or by reliable pumping facilities.